



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Tom Pruno
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

12/20/2017

Phone: (856) 616-9516
Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/6/2017. The results are tabulated on the attached data pages for the following client designated project:

HTPS - Hillsborough High School / PR-171031-1172

The reference number for these samples is EMSL Order #011709699. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709699
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/06/17 12:55 PM

Project: **HPS - Hillsborough High School / PR-171031-1172**

Analytical Results

Client Sample Description HHS-1206-01
 HHS-1-AEROBIC-DW; WF; Aerobics / Wrestling Room
Collected: 12/6/2017 **Lab ID:** 011709699-0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/14/2017	SM	12/14/2017	SM

Client Sample Description HHS-1206-02
 HHS-1-WR-DW;WF; Weight Room by Aerobics
Collected: 12/6/2017 **Lab ID:** 011709699-0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/14/2017	SM	12/14/2017	SM

Client Sample Description HHS-1206-03
 HHS-1-HWR-WC1; WF; Hallway Across from Weight Room
Collected: 12/6/2017 **Lab ID:** 011709699-0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/14/2017	SM	12/14/2017	SM

Client Sample Description HHS-1206-04
 HHS-1-HWR-WC2; WF; Hallway Across from Weight Room
Collected: 12/6/2017 **Lab ID:** 011709699-0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/14/2017	SM	12/14/2017	SM

Client Sample Description HHS-1206-05
 HHS-1-BGYM-DW; WF; In Gym B
Collected: 12/6/2017 **Lab ID:** 011709699-0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.34	1.00	µg/L	12/14/2017	SM	12/14/2017	SM

Client Sample Description HHS-1206-06
 HHS-1-CGYM-ENT-WC1;WF; Entrance Lobby to Gym C
Collected: 12/6/2017 **Lab ID:** 011709699-0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/14/2017	SM	12/14/2017	SM

Client Sample Description HHS-1206-07
 HHS-1-CGYM-ENT-WC2;WF; Entrance Lobby to Gym C
Collected: 12/6/2017 **Lab ID:** 011709699-0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/14/2017	SM	12/14/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709699
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/06/17 12:55 PM

Project: **HPS - Hillsborough High School / PR-171031-1172**

Analytical Results

Client Sample Description HHS-1206-08
 HHS-1-TRAINER-IM1; IM; Trainer's Room
Collected: 12/6/2017 **Lab ID:** 011709699-0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/14/2017	SM	12/14/2017	SM

Client Sample Description HHS-1206-09
 HHS-1-TRAINER-IM2; IM; Trainer's Room
 Next To Hot Tub
Collected: 12/6/2017 **Lab ID:** 011709699-0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/14/2017	SM	12/14/2017	SM

Client Sample Description HHS-1206-10
 HHS-1-TRAINER-CF; Sink Faucet;
 Trainer's Room
Collected: 12/6/2017 **Lab ID:** 011709699-0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/14/2017	SM	12/14/2017	SM

Client Sample Description HHS-1206-11
 HHS-1-Between A-BGYM-DW; WF;
 Vestibule Between Gym A & Gym B
Collected: 12/6/2017 **Lab ID:** 011709699-0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/14/2017	SM	12/14/2017	SM

Client Sample Description HHS-1206-12
 HHS-1-Faculty Dining-TF; Sink Faucet;
 Faculty Dining
Collected: 12/6/2017 **Lab ID:** 011709699-0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.16	1.00	µg/L	12/14/2017	SM	12/14/2017	SM

Client Sample Description HHS-1206-13
 HHS-1-LIBOFFICE-524-TF; Sink Faucet;
 Media Center Office
Collected: 12/6/2017 **Lab ID:** 011709699-0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/14/2017	SM	12/14/2017	SM

Client Sample Description HHS-1206-14
 HHS-1-HEC520-CF12; Sink Faucet; Home
 Ec Room 520
Collected: 12/6/2017 **Lab ID:** 011709699-0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011709699

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/06/17 12:55 PM

Project: HTPS - Hillsborough High School / PR-171031-1172

Analytical Results

Client Sample Description HHS-1206-15
 HHS-1-HEC520-CF34; Sink Faucet; Home Ec Room 520
Collected: 12/6/2017 **Lab ID:** 011709699-0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-16
 HHS-1-HEC520-CF56; Sink Faucet; Home Ec Room 520
Collected: 12/6/2017 **Lab ID:** 011709699-0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-17
 HHS-1-H515-WC1; WF; Hallway Across From Room 515
Collected: 12/6/2017 **Lab ID:** 011709699-0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-18
 HHS-1-H515-WC3; WF; Hallway Across From Room 515
Collected: 12/6/2017 **Lab ID:** 011709699-0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-19
 HHS-1-HEC515-CF1; Sink Faucet; Home Ec Room 515
Collected: 12/6/2017 **Lab ID:** 011709699-0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-20
 HHS-1-HEC515-CF2; Sink Faucet; Home Ec Room 515
Collected: 12/6/2017 **Lab ID:** 011709699-0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-21
 HHS-1-HEC515-CF3; Sink Faucet; Home Ec Room 515
Collected: 12/6/2017 **Lab ID:** 011709699-0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.27	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709699
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/06/17 12:55 PM

Project: **HTPS - Hillsborough High School / PR-171031-1172**

Analytical Results

Client Sample Description HHS-1206-22
 HHS-1-HEC515-CF4; Sink Faucet; Home Ec Room 515
Collected: 12/6/2017 **Lab ID:** 011709699-0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.25	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-23
 HHS-1-HEC515-CF5; Sink Faucet; Home Ec Room 515
Collected: 12/6/2017 **Lab ID:** 011709699-0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-24
 HHS-1-HEC515-CF6; Sink Faucet; Home Ec Room 515
Collected: 12/6/2017 **Lab ID:** 011709699-0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-25
 HHS-1-HEC515-CF7; Sink Faucet; Home Ec Room 515
Collected: 12/6/2017 **Lab ID:** 011709699-0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-26
 HHS-1-510-CF1; Sink Faucet; Room 510 (Regular Sink)
Collected: 12/6/2017 **Lab ID:** 011709699-0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-27
 HHS-1-510-CF2; Sink Faucet; Room 510 (Regular Sink)
Collected: 12/6/2017 **Lab ID:** 011709699-0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-28
 HHS-1-510-CF3; Sink Faucet; Room 510 (Regular Sink)
Collected: 12/6/2017 **Lab ID:** 011709699-0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709699
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/06/17 12:55 PM

Project: **HPS - Hillsborough High School / PR-171031-1172**

Analytical Results

Client Sample Description HHS-1206-29
 HHS-1-510-CF4; Sink Faucet; Room 510
 (Regular Sink) **Collected:** 12/6/2017 **Lab ID:** 011709699-0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.48	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-30
 HHS-1-COMMONS-WC1;WF; In Commons Area **Collected:** 12/6/2017 **Lab ID:** 011709699-0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-31
 HHS-1-COMMONS-WC3;WF; In Commons Area **Collected:** 12/6/2017 **Lab ID:** 011709699-0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-32
 HHS-1-CUSTODIAN-320-TF; Sink Faucet In Custodian Office (320) **Collected:** 12/6/2017 **Lab ID:** 011709699-0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-33
 HHS-1-H319-DW; WF; Hallway By Room 319 **Collected:** 12/6/2017 **Lab ID:** 011709699-0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.67	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-34
 HHS-317-BR-WC; WF; In Room 317 (Band) **Collected:** 12/6/2017 **Lab ID:** 011709699-0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-35
 HHS-315-BR-WC; WF; In Room 315 (Band) **Collected:** 12/6/2017 **Lab ID:** 011709699-0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709699
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/06/17 12:55 PM

Project: **HPS - Hillsborough High School / PR-171031-1172**

Analytical Results

Client Sample Description HHS-1206-36
 HHS-315A-BR-CF; Sink Faucet; Room 315
 Office (Band) **Collected:** 12/6/2017 **Lab ID:** 011709699-0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.61	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-37
 HHS-1-H314-DW; WF; Hallway By Room
 314 **Collected:** 12/6/2017 **Lab ID:** 011709699-0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-38
 HHS-1-312-CF; Sink Faucet; Room 312 **Collected:** 12/6/2017 **Lab ID:** 011709699-0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-39
 HHS-1-312-IM; IM; Room 312 **Collected:** 12/6/2017 **Lab ID:** 011709699-0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-40
 HHS-1-307-TF; Sink Faucet; Room 307F
 (CST Kitchenette) **Collected:** 12/6/2017 **Lab ID:** 011709699-0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.87	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-41
 HHS-1-HN304E-WC;WF; Nurse Area 304E **Collected:** 12/6/2017 **Lab ID:** 011709699-0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-42
 HHS-1-N304E-NS; Sink Faucet; Nurse Area
 304E **Collected:** 12/6/2017 **Lab ID:** 011709699-0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709699
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/06/17 12:55 PM

Project: **HTPS - Hillsborough High School / PR-171031-1172**

Analytical Results

Client Sample Description HHS-1206-43
 HHS-1-N304A-NS; Sink Faucet; Nurse Area
 304A
Collected: 12/6/2017 **Lab ID:** 011709699-0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-44
 HHS-1-NS-CF; Sink Faucet; Nurse Area

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.09	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-45
 HHS-1-TRAINER-HB; HB; Exterior Across
 From Trainer's Room

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/18/2017	TD	12/18/2017	JW

Client Sample Description HHS-1206-46
 HHS-FH-FITNESS ROOM-WC; WF; Field
 House; Fitness/Visitor Locker Room

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-47
 HHS-FH-LR-WC; WF; Field House; Home
 Locker Room

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.11	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-48
 HHS-FH-LR-LRS; Sink Faucet; Field
 House; Home Locker Room

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.63	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-49
 HHS-FH-KITCHEN-FP; Sink Faucet; Field
 House Kitchen; Food Prep

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	14.7	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011709699

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/06/17 12:55 PM

Project: **HTPS - Hillsborough High School / PR-171031-1172****Analytical Results**

Client Sample Description HHS-1206-50
 HHS-FH-KITCHEN-IM; IM; Field House
 Kitchen
Collected: 12/6/2017 **Lab ID:** 011709699-0050

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.0	1.00	µg/L	12/18/2017	TD	12/18/2017	JW

Client Sample Description HHS-1206-51
 HHS-FH-BBR-WC;WF; Field House; Boys
 Restroom
Collected: 12/6/2017 **Lab ID:** 011709699-0051

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-52
 HHS-FH-GBR-WC; WF; Field House; Girls
 Restroom
Collected: 12/6/2017 **Lab ID:** 011709699-0052

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/15/2017	SM	12/15/2017	SM

Client Sample Description HHS-1206-53
 HHS-FH-EXTERIOR-HB; HB; Field House;
 Exterior By Electric Room
Collected: 12/6/2017 **Lab ID:** 011709699-0053

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.2	1.00	µg/L	12/18/2017	SM	12/18/2017	SM

Client Sample Description HHS-1206-54
 QC Blank; DI Blank
Collected: 12/6/2017 **Lab ID:** 011709699-0054

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/18/2017	SM	12/18/2017	SM

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Tom Pruno
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

12/20/2017

Phone: (856) 616-9516
Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/8/2017. The results are tabulated on the attached data pages for the following client designated project:

HTPS - Hillsborough High School / PR-171031-1172

The reference number for these samples is EMSL Order #011709794. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709794
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/08/17 1:30 PM

Project: **HPS - Hillsborough High School / PR-171031-1172**

Analytical Results

Client Sample Description HHS-1208-55
 HHS-1-KITCHEN-FP1; Sink Faucet;
 Kitchen; Food Prep
Collected: 12/8/2017 **Lab ID:** 011709794-0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

Client Sample Description HHS-1208-56
 HHS-1-KITCHEN-FP2; Sink Faucet;
 Kitchen; Food Prep
Collected: 12/8/2017 **Lab ID:** 011709794-0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

Client Sample Description HHS-1208-57
 HHS-1-KITCHEN-FP3; Sink Facuet;
 Kitchen; Food Prep
Collected: 12/8/2017 **Lab ID:** 011709794-0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

Client Sample Description HHS-1208-58
 HHS-1-KITCHEN-KT1; KT; Kitchen; Kettle
Collected: 12/8/2017 **Lab ID:** 011709794-0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

Client Sample Description HHS-1208-59
 HHS-1-KITCHEN-KT2; KT; Kitchen; Kettle
Collected: 12/8/2017 **Lab ID:** 011709794-0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.63	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

Client Sample Description HHS-1208-60
 HHS-1-KITCHEN-KT3; KT; Kitchen; Kettle
Collected: 12/8/2017 **Lab ID:** 011709794-0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

Client Sample Description HHS-1208-61
 HHS-1-SERVING-FP1; Sink Faucet;
 Serving Area; Food Prep
Collected: 12/8/2017 **Lab ID:** 011709794-0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709794
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/08/17 1:30 PM

Project: **H7PS - Hillsborough High School / PR-171031-1172**

Analytical Results

Client Sample Description HHS-1208-62
 HHS-1-SERVING-FP2; Sink Faucet;
 Serving Area; Food Prep
Collected: 12/8/2017 **Lab ID:** 011709794-0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.02	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

Client Sample Description HHS-1208-63
 HHS-1-KITCHEN-IM; IM; Kitchen
Collected: 12/8/2017 **Lab ID:** 011709794-0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

Client Sample Description HHS-1208-64
 HHS-2-H713-WC; WF; Hallway by Room
 713
Collected: 12/8/2017 **Lab ID:** 011709794-0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/11/2017	SM	12/11/2017	SM

Client Sample Description HHS-1208-65
 HHS-2-H705-WC1; WF; Hallway by Room
 705
Collected: 12/8/2017 **Lab ID:** 011709794-0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/11/2017	SM	12/11/2017	SM

Client Sample Description HHS-1208-66
 HHS-2-H705-WC2; WF; Hallway by Room
 705
Collected: 12/8/2017 **Lab ID:** 011709794-0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2017	SM	12/19/2017	SM

Client Sample Description HHS-1208-67
 HHS-2-H617-WC1; WF; Hallway by Room
 617
Collected: 12/8/2017 **Lab ID:** 011709794-0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/11/2017	SM	12/11/2017	SM

Client Sample Description HHS-1208-68
 HHS-2-H617-WC3; WF; Hallway by Room
 617
Collected: 12/8/2017 **Lab ID:** 011709794-0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/11/2017	SM	12/11/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709794
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/08/17 1:30 PM

Project: HTPS - Hillsborough High School / PR-171031-1172

Analytical Results

Client Sample Description HHS-1208-69
 HHS-2-617-TF; Sink Faucet; Room 617
Collected: 12/8/2017 **Lab ID:** 011709794-0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/11/2017	SM	12/11/2017	SM

Client Sample Description HHS-1208-70
 HHS-2-H802-WC1; WF; Hallway by Room 802
Collected: 12/8/2017 **Lab ID:** 011709794-0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/11/2017	SM	12/11/2017	SM

Client Sample Description HHS-1208-71
 HHS-2-H802-WC2; WF; Hallway by Room 802
Collected: 12/8/2017 **Lab ID:** 011709794-0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/11/2017	SM	12/11/2017	SM

Client Sample Description HHS-1208-72
 HHS-2-H812-WC; WF; Hallway by Room 812
Collected: 12/8/2017 **Lab ID:** 011709794-0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/11/2017	SM	12/11/2017	SM

Client Sample Description HHS-1208-73
 HHS-1-MO-TF; Sink Facuet; Main Office
Collected: 12/8/2017 **Lab ID:** 011709794-0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.01	1.00	µg/L	12/11/2017	SM	12/11/2017	SM

Client Sample Description HHS-1208-74
 HHS-102-TO-CF; Sink Faucet; Room 102
Collected: 12/8/2017 **Lab ID:** 011709794-0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.07	1.00	µg/L	12/11/2017	SM	12/11/2017	SM

Client Sample Description HHS-1208-75
 HHS-1-H106-DW1; WF; Hallway by Room 106
Collected: 12/8/2017 **Lab ID:** 011709794-0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709794
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/08/17 1:30 PM

Project: **HTPS - Hillsborough High School / PR-171031-1172**

Analytical Results

Client Sample Description HHS-1208-76
 HHS-1-H106-DW2; WF; Hallway by Room
 106
Collected: 12/8/2017 **Lab ID:** 011709794-0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.00	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-77
 HHS-1-H106-DW3; WF; Hallway by Room
 106
Collected: 12/8/2017 **Lab ID:** 011709794-0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.17	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-78
 HHS-1-H114-CF; Sink Faucet; Room 114
Collected: 12/8/2017 **Lab ID:** 011709794-0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.24	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-79
 HHS-1-H138-DW; WF; Hallway by Room
 138
Collected: 12/8/2017 **Lab ID:** 011709794-0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-80
 HHS-1-H144-DW; WF; Hallway by Room
 144
Collected: 12/8/2017 **Lab ID:** 011709794-0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-81
 HHS-1-H164-DW1; WF; Hallway by Room
 164
Collected: 12/8/2017 **Lab ID:** 011709794-0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.49	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-82
 HHS-1-H164-DW2; WF; Hallway by Room
 164
Collected: 12/8/2017 **Lab ID:** 011709794-0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.22	1.00	µg/L	12/12/2017	SM	12/12/2017	SM



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709794
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/08/17 1:30 PM

Project: **HPS - Hillsborough High School / PR-171031-1172**

Analytical Results

Client Sample Description HHS-1208-83
 HHS-2-H229-DW; WF; Hallway by Room
 229
Collected: 12/8/2017 **Lab ID:** 011709794-0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.54	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-84
 HHS-2-H235-DW; WF; Hallway by Room
 235
Collected: 12/8/2017 **Lab ID:** 011709794-0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-85
 HHS-2-H242-WC; WF; Hallway by Room
 242
Collected: 12/8/2017 **Lab ID:** 011709794-0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-86
 HHS-2-H255-DW1; WF; Hallway by Room
 255
Collected: 12/8/2017 **Lab ID:** 011709794-0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.35	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-87
 HHS-2-H255-DW2; WF; Hallway by Room
 255
Collected: 12/8/2017 **Lab ID:** 011709794-0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-88
 HHS-2-H255-DW3; WF; Hallway by Room
 255
Collected: 12/8/2017 **Lab ID:** 011709794-0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.16	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-89
 HHS-2-260-TF; Sink Faucet; Room 260
Collected: 12/8/2017 **Lab ID:** 011709794-0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709794
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/08/17 1:30 PM

Project: **HTPS - Hillsborough High School / PR-171031-1172**

Analytical Results

Client Sample Description HHS-1208-90
 HHS-2-262-TF; Sink Faucet; Room 262
Collected: 12/8/2017 **Lab ID:** 011709794-0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-91
 HHS-2-HVPO-CF; Sink Faucet; 2nd Floor
 Main Office
Collected: 12/8/2017 **Lab ID:** 011709794-0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-92
 HHS-2-H203-CF; Sink Facuet; Room 203
Collected: 12/8/2017 **Lab ID:** 011709794-0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.16	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-93
 HHS-2-H206-DW1; WF; Hallway by Room
 206
Collected: 12/8/2017 **Lab ID:** 011709794-0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.05	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-94
 HHS-2-H206-DW2; WF; Hallway by Room
 206
Collected: 12/8/2017 **Lab ID:** 011709794-0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-95
 HHS-2-H224-DW; WF; Hallway by Room
 224
Collected: 12/8/2017 **Lab ID:** 011709794-0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.99	1.00	µg/L	12/12/2017	SM	12/12/2017	SM

Client Sample Description HHS-1208-96
 QC Blank; DI Blank
Collected: 12/8/2017 **Lab ID:** 011709794-0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/12/2017	SM	12/12/2017	SM



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

EMSL Order: 011709794

CustomerID: EDI50

CustomerPO:

ProjectID:

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)